









Cross Connection Control Program - Requirement Reference Sheet

Backflow Preventer:	Specific Required Corrective Action:	Required ?
	<p><u>Lawn Sprinkler Backflow Preventers</u> If box "A" is checked -Install Pressure Vacuum Breaker with Product Standard Approval # ASSE 1020 in Supply to Lawn Irrigation System. Device must be tested and registered with the Dept of Commerce by a Certified Tester upon installation. <u>Location/Comments:</u></p>	A <input type="checkbox"/>
	<p><u>Toilet Tank Anti-Siphon Valves</u> If box "B" is checked -Install Anti-Siphon Ballcock Assembly with Product Standard Approval # ASSE 1002 inside toilet water tank. This device may be installed by homeowner and purchased for less than \$20 at hardware/home improvement stores. <u>Location/Comments:</u></p>	B <input type="checkbox"/>
	<p><u>Boiler Backflow Preventer – High Hazard Type</u> If box "C" is checked -Install Reduced Pressure Principle Backflow Preventer with Product Standard Approval # ASSE 1013 in Supply to Chemically Treated Boiler System. Device must be tested and registered with the Dept of Commerce by a Certified Tester upon installation. <u>Location/Comments:</u></p>	C <input type="checkbox"/>
	<p><u>Boiler Backflow Preventer – Low Hazard Type</u> If box "D" is checked -Install Vented Dual Check Valve Product Standard Approval # ASSE 1012 in Supply to Non-Chemically Treated Boiler System. Consult a licensed plumber for proper installation. <u>Location/Comments:</u></p>	D <input type="checkbox"/>
	<p><u>Outside Hose Bibb Fixture</u> If box "E" is checked - Install Hose Bibb Vacuum Breaker Product Standard Approval # ASSE 1011 on hose threads of hose bibb or install ASSE # 1019 fixture. For cold weather/season installation, make sure hose is disconnected and relief valve has drained any water contained within the hose bibb. During winter/ below freezing weather, shut off interior control valve supply to each exterior hose bibb and open to drain the hose bibb fixture to prevent freezing and expansion damage. <u>Location/Comments:</u></p>	E <input type="checkbox"/>
	<p><u>Standard Hose Bibb</u> If box "F" is checked - Install Hose Bibb Vacuum Breaker Product Standard Approval # ASSE 1011 on hose threads of hose bibb. This device may be installed by homeowner and purchased for less than \$15 at hardware/home improvement stores. <u>Location/Comments:</u></p>	F <input type="checkbox"/>
	<p><u>Laundry Tub Threaded Fixture</u> If box "G" is checked - Install Hose Connection Vacuum Breaker Product Standard Approval # ASSE 1011 on hose threads of Laundry Tub Faucet. This device may be installed by homeowner and purchased for less than \$15 at hardware/home improvement stores. <u>Location/Comments:</u></p>	G <input type="checkbox"/>
	<p><u>Water Softener Back Flush Drain Hose</u> If box "H" is checked - Install a minimum 1" physical air gap between Back Flush Drain Piping or install an open ended "T" with elbow in the downward position and open to atmosphere to prevent backflow potential. This correction may be installed by homeowner and corrected for less than \$15 with materials available at hardware/home improvement stores. <u>Location/Comments:</u></p>	H <input type="checkbox"/>