

## Village of East Troy PFAS Sampling Results 2022

Compound	Well 5	Well 6	Well 7	Well 8	WI DHS MCL	WI DHS PAL
PFBA				1.86 ng/L	10,000 ng/L	2,000 ng/L
PFPeA				0.233 ng/L	None	None
PFBS		2.02 ng/L		6.36 ng/L	450,000 ng/L	90,000 ng/L
PFHxA				0.573 ng/L	150,000 ng/L	30,000 ng/L
PFPeS				0.786 ng/L	None	None
PFHxS				12.1 ng/L	40 ng/L	4 ng/L
6:2 FTSA				0.513 ng/L	None	None
PFOA				0.781 ng/L	20 ng/L	2ng/L
PFHpS				0.631 ng/L	None	None
PFOS				8.32 ng/L	20 ng/L	2ng/L

ng/L=nanograms/liter; MCL=Maximum Containment Level; PAL=Preventative Action Limit